



REQUIRED FIRE INSPECTIONS

COMMERCIAL PERMITS

- Penetration Assembly Protection
- Fire Barrier Wall Rough
- Fire Barrier Wall Final
- Stair Rough
- Stair Final
- Guardrail/Handrail
- Fire/Smoke Dampers
- Fire Doors/Frames/Hardware
- Life Safety Generator Load Bank Test
- FINAL FIRE COMPLIANCE (ie: smoke alarms, fire extinguisher, emergency lights, exits signs, etc)

LPG TANK/PIPING

- LPG Tank Installation
- LPG Tank Anchor & Foundation Insp - 30 min
- LPG Pipe Rough Pressure Test
- LPG Final Pressure Manometer Test

SUPPRESSION SYSTEMS

- Fire Suppression System Inspection

GREASE HOOD

- Exhaust Hood/Ducts
- Smoke Test
- Light Test

FIRE ALARM

- Rough-In
- Supervisory/Monitoring
- Fire Alarm Final

NATURAL GAS

- LPG/Nat Gas/Pipe Rough/Pressure
- LPG/Nat Gas Final Pressure Manometer

U/G FIRE LINE

- Underground Pipe Installation
- Flush Test *(through BSU)*
- Hydro Test

FIRE SPRINKLER

- Rough/Hydro
- Sprinkler Final

FIRE PUMP

- Rough/Hydro
- Fire Pump Final

BACKFLOW

- Installation
- Hydro
- Sprinkler Final

STANDPIPE

- Rough/Hydro
- Standpipe Final

This is a comprehensive list of required fire inspections for your new construction project. There may be additional inspections required, not on this list. For any questions regarding inspections or inspection scheduling, please email: consinsp@bonitafire.org.